



Product certificate
K 13314/03

Issued 2014-07-01

Replaces K13314/02

Page 1 of 3


Vulcanised rubber products for cold and hot drinking water applications

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Terramix, S.A./Hultec

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K17504 "Vulcanised rubber products for cold and hot drinking water applications".



Bouke Meekma
Kiwa

Publication of the certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Supplier

Terramix, S.A./Hultec
150 mts al este y 150 al sur
Pozos de Santa Ana
San Jose
Costa Rica

Tel +506 282 99 00
Fax +506 282 35 68
E-mail hultec@hultec.com
www.hultec.com

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 70 414 44 00
Fax +31 70 414 44 20
info@kiwa.nl
www.kiwa.nl

Certification process
consists of initial and
regular assessment of:









Certificate

Vulcanised rubber products for cold and hot drinking water applications

PRODUCT SPECIFICATION

The products as specified in the table below fulfil the requirements of BRL-K17504. BRL-K17504 covers the requirements of EN 681-1, "Elastomeric seals - Materials requirements for pipe joint seals used in water and drainage applications - Part 1: Vulcanized rubber".


TECHNICAL SPECIFICATION OF THE PRODUCT

Rubber Compound:	EPDM HT 5557			
Hardness:	55 IRHD	Field of application ² :	I – WA	Remarks:
Ozone Class ¹ :	I	Production method:	Injection mold	
Seal type	Tyton Ring	 		
Nominal Dimensions	80 - 1000 mm			
Cross section	0,6 – 1,4 mm			
Rubber Compound:	EPDM HT 5607			
Hardness:	60 IRHD	Field of application ² :	I – WA	Remarks:
Ozone Class ¹ :	I	Production method:	Injection mold	
Seal type	Plastic Retainer Ring	 		
Nominal Dimensions	63 - 315 mm			
Cross section	12 – 43 mm			
Seal type	Platinum Pressure Ring	  		
Nominal Dimensions	50 - 630 mm			
Cross section	8 – 77 mm			
Seal type	Metric Turner			
Nominal Dimensions	50 – 400 mm			
Cross section	9 - 31 mm			
<p>1 Ozone resistance class according to BRL-K17504:</p> <p>I For products with a high risk of attack by ozone, for instance in case of separately supplied products without sufficient packaging or in case of connections with preinstalled rubbers under strain;</p> <p>II For products for which a normal resistance to ozone is required;</p> <p>III For rubbers which are never (partly) exposed to the open air when they are in tension. Transport shall always take place in sealed packages.</p> <p>2 Field of application class according to BRL-K17504:</p> <p>I Water supply at temperatures up to 50°C;</p> <p>II Hot water supply at temperatures intermittently up to 110 °C, or water supply up to 110 °C in serviceable piping systems;</p> <p>III Hot water circulation systems based on the classification class 2 in ISO 10508;</p> <p>Field of application according to EN 681-1:</p> <p>WA As in BRL-K17504 class I;</p> <p>WB As in BRL-K17504 class II;</p> <p>WE As in BRL-2013 class II, for IIR-copolymer;</p>				

Details of the products are included in the drawing list, which forms a part of the IQC schedule. Kiwa authenticates this list. A copy of this list can be obtained from the producer.

MARKING

The following marks and indications must be provided on each product[#] and product packaging in a clear, legible and indelible way:

- the name of manufacturer or the deposited trade mark;
- Kiwa (or Kiwa® word mark) and additionally the Kiwa watermark ;
- the nominal dimension or dimensions;
- the nominal hardness;
- the year of manufacturing and preferably the quarter;
- type of rubber applied by means of the letter codes of the nomenclature according to ISO 1629;
- the application class (I, II or III);
- on products from blends, the letter B ("blend") shall be placed behind the first letter code;
- the ozone resistance class ("Ozone I, II or III"). For rubber rings made from two compounds the compound with the lowest class is valid.

[#] If the dimensions of the products are such that the indications applied to them may impair the product, the products may be marked per package in consultation with the manufacturer, the buyer and Kiwa. Products produced by cutting or die cutting out of sheets may be marked per package.

Vulcanised rubber products for cold and hot drinking water applications

TOXICOLOGICAL REQUIREMENTS

Approval:

This product is approved on the basis of the requirements set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Regulation materials and chemicals drinking water and warm tap water supply"; published in the Government Gazette).

ATA criteria:

The ATA product certification is based on two main criteria. It shall permanently comply with:

- The product recipe approved during the assessment procedure. The recipe is laid down in the for confidentiality reasons undisclosed appendix ATA to certificate K13314. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa-ATA-approval procedure;
- Specific ATA-product requirements, laid down in appendix ATA to certificate K13314. For confidentiality reasons this appendix ATA is not public.

Field of application:

The rubber rings are meant to be used in cold water applications ($\leq 25^\circ$).

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Terramix, S.A./Hultec
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.