


## Gasketed PVC Pipe



PVC Product	Nominal Pipe Size (inches)	Average Outside Diameter (inches)	Maximum Bell Outside Diameter (inches)
ASTM D2241 IPS	2	2.375	3 <sup>3</sup> / <sub>8</sub>
	2 1/2	2.875	4 <sup>1</sup> / <sub>8</sub>
	3	3.500	4 <sup>7</sup> / <sub>8</sub>
	4	4.500	6
	5	5.563	7 <sup>1</sup> / <sub>4</sub>
	6	6.625	8 <sup>1</sup> / <sub>2</sub>
	8	8.625	11
	10	10.750	13 <sup>1</sup> / <sub>2</sub>
12	12.750	15 <sup>3</sup> / <sub>4</sub>	
AWWA C900 AWWA C909	4	4.800	6 <sup>7</sup> / <sub>8</sub>
	6	6.900	9 <sup>1</sup> / <sub>2</sub>
	8	9.050	12 <sup>1</sup> / <sub>8</sub>
	10	11.100	14 <sup>7</sup> / <sub>8</sub>
	12	13.200	17 <sup>3</sup> / <sub>8</sub>
AWWA C905 AWWA C909	14	15.300	19 <sup>1</sup> / <sub>2</sub>
	16	17.400	21 <sup>7</sup> / <sub>8</sub>
	18	19.500	24 <sup>3</sup> / <sub>8</sub>
	20	21.600	26 <sup>7</sup> / <sub>8</sub>
	24	25.800	31 <sup>1</sup> / <sub>8</sub>
ASTM D3034 Sewer and Stormdrain	4	4.215	5 <sup>1</sup> / <sub>8</sub>
	6	6.275	7 <sup>1</sup> / <sub>2</sub>
	8	8.400	9 <sup>3</sup> / <sub>4</sub>
	10	10.500	12
	12	12.500	14 <sup>1</sup> / <sub>2</sub>
	15	15.300	18 <sup>1</sup> / <sub>4</sub>
ASTM F 679 Sewer and Stormdrain	18	18.701	22 <sup>1</sup> / <sub>8</sub>
	21	22.047	26
	24	24.803	29
ASAE S376.1 PIP	6	6.140	7 <sup>5</sup> / <sub>8</sub>
	8	8.160	9 <sup>7</sup> / <sub>8</sub>
	10	10.200	12
	12	12.240	14 <sup>3</sup> / <sub>8</sub>
	15	15.300	19
	18	18.701	22 <sup>1</sup> / <sub>4</sub>
	21	22.047	26 <sup>1</sup> / <sub>4</sub>
	24	24.803	29 <sup>1</sup> / <sub>4</sub>

## Maximum Bell Outside Diameters Solvent-Weld PVC Pipe



PVC Product	Nominal Pipe Size (inches)	Average Outside Diameter (inches)	Maximum Bell Outside Diameter (inches)
<b>ASAE S376.1 PIP</b>	6	6.140	6 <sup>3</sup> / <sub>4</sub>
	8	8.160	8 <sup>7</sup> / <sub>8</sub>
	10	10.200	11
	12	12.240	13 <sup>1</sup> / <sub>4</sub>
	15	15.300	16 <sup>1</sup> / <sub>2</sub>
<b>100 FT Head IP</b>	18	18.360	19 <sup>1</sup> / <sub>8</sub>
	20	20.400	21 <sup>1</sup> / <sub>8</sub>
<b>ASTM D2241 *IPS</b>	<sup>1</sup> / <sub>2</sub>	0.840	1 <sup>3</sup> / <sub>8</sub>
	<sup>3</sup> / <sub>4</sub>	1.050	1 <sup>1</sup> / <sub>2</sub>
	1	1.315	1 <sup>7</sup> / <sub>8</sub>
	1 <sup>1</sup> / <sub>4</sub>	1.660	2 <sup>1</sup> / <sub>4</sub>
	1 <sup>1</sup> / <sub>2</sub>	1.900	2 <sup>1</sup> / <sub>2</sub>
	2	2.375	3
	2 <sup>1</sup> / <sub>2</sub>	2.875	3 <sup>5</sup> / <sub>8</sub>
	3	3.500	4 <sup>3</sup> / <sub>8</sub>
	3 <sup>1</sup> / <sub>2</sub>	4.000	4 <sup>7</sup> / <sub>8</sub>
	4	4.500	5 <sup>1</sup> / <sub>2</sub>
	5	5.563	6 <sup>5</sup> / <sub>8</sub>
	6	6.625	7 <sup>3</sup> / <sub>4</sub>
8	8.625	9 <sup>3</sup> / <sub>4</sub>	
10	10.750	12 <sup>1</sup> / <sub>8</sub>	
12	12.750	14 <sup>3</sup> / <sub>8</sub>	
<b>ASTM D3034 Sewer</b>	3	3.250	3 <sup>3</sup> / <sub>4</sub>
	4	4.215	4 <sup>3</sup> / <sub>4</sub>
<b>C-Duct</b>	4	4.350	5

\* "IPS" includes electrical conduit and utility duct in addition to IPS water pipe.